



Ymir Water System

2021 Quartz Creek Flow and Water Quality Monitoring Report

Flow and Turbidity Quarterly Report

Date of Report:	23 March 2022
Reporting Period:	2021 Year End Report 14 Oct 2021 to 19 Jan 2022
Owner:	Regional District of Central Kootenay
Contact:	Jason McDiarmid, Utility Services Manager (250) 352-8169, jmcdiarmid@rdck.bc.ca

1. Quartz Creek Flow Monitoring

1.1 Reporting Period

The reporting for this report is Fourth Quarter 2021 and includes data from 01 January 2021 to 19 Jan 2022. See prior years reporting for additional data and flow monitoring information.

1.2 Flow Monitoring Weir

In 2019 a flow monitoring weir was installed on Quartz Creek at the intake for the Ymir water system with funding provided by BC Timber Sale and the water service. Funding for current monitoring and reporting is provided by ATCO Wood Products Ltd. and the Regional District owned Ymir water service.


The Kindsvater-Carter Formula was adopted to calculate flow through the sharp crested aluminum weir installed in the concrete water system intake weir. Flow depth through the aluminum flow monitoring weir is measured by an ultrasonic level transmitter. The aluminum weir will measure flows up to about 560 mm or 742 L/s, above this level the concrete intake weir will overtop. Wing plates were added to the ends of the concrete weir to accommodate higher peak flows of up to 710 mm or 1,515 L/s.

1.3 Reporting Period Data Quality



The level sensor failed for a second time on 17 August 2021. The sensor was warranted by the supplier and the new sensor was installed on 13 October 2021. The lowest flow level for the period was recorded immediately before the sensor failure.

1.4 Flow Graphs

The Quartz Creek level and flow data is provided in 15 minute intervals, which is too much data to chart. The digital flow data is provided in a separate Excel file. An Excel pivot table was used to present the following daily average weir flow level, creek flows and turbidity data.



When the level sensor failed, visual flow level readings were recorded about once per week. The following charts provide a comparison of instrument level recordings versus visual level recordings, and the associated calculated flows rates.




The following table provides the minimum and maximum average daily weir flow level and creek flows for the reporting period.

	Quartz Creek Flow Level (mm)	Quartz Creek Flow (L/s)	Date
Min	25	7.6	See Note 1
Max	618	1,057	30 Apr 2021

Note 1: The lowest flow levels recorded for the monitoring period occurred during the level sensor failure period and were observed visually. A 1 inch (25 mm) flow level was recorded on 28 July, 03 August, 30 August, 07 September, 27 September, 05 October, and 18 October 2021.

1.5 Regional District Saso Consulting Flow Monitoring Data Comparison

Saso Consulting is also monitoring Quartz Creek flows above the Regional District Ymir water system intakes. The following chart provides a comparison of the average daily 2021 flow monitoring data up to the point of Regional District level sensor failure.



The Regional District and Saso flow data correlates reasonably well, particularly at lower flow rates, considering the flow data is based on different flow monitoring approaches. Regional District flows are calculated based on flow levels through a flow monitoring weir and Saso flows are calculated based on flow levels through a natural creek section.

The Regional District flows differ from Saso flows in that the Regional District flows do not include flows diverted to the Ymir water treatment plant. Daily average treatment plant flows are relatively insignificant compared to creek flows during low water system demand periods.

Flow results vary around February 2021. This can possibly be attributed to creek or flow monitoring weir area icing.

Up to about the end of April Regional District flows were generally lower than Saso flows. From the end of April to the beginning of July Regional District flows were higher than Saso flows. Flow rate correlated well from the beginning of July to the beginning of August.

2. Quartz Creek Water Quality Monitoring

The Regional District is monitoring the following water quality parameters in association with the Quartz Creek Flow and Water Quality Monitoring initiative.

Water Quality Monitoring Parameter	Description	Desired Frequency
Raw Water Turbidity	Online turbidity meter	15 minutes
pH	Manual testing	When Technician on Site
Treated Water Bacteriological	Total Coliforms, E.coli & Fecal Coliform	Weekly
Raw Water Bacteriological	Total Coliforms, E.coli & Fecal Coliform	Bi-weekly
Raw Water Full Comprehensive	Chemical and physical parameters based on Guidelines for Canadian Drinking Water Quality	Quarterly
Treated Water THM & HAA	Trihalomethanes (THMs) and haloacetic acids (HAAs)	Quarterly


2.1 Raw Water Turbidity

Raw water turbidity is monitored online in the treatment plant.

Raw water turbidity is presented on the flow charts in the previous section. The maximum daily average turbidity for the reporting period was 4.27 NTU recorded on 02 May 2021, during freshet.

2.2 pH

pH is hand measured when water technicians are onsite at the Ymir water treatment plant. The following chart provides the pH test results for the monitoring period. pH varied from 7.0 to 7.7 during the monitoring period. The slight variations do not appear to correlate with seasons or flow rates.



2.3 Treated Water Bacteriological


A treated water sample is taken weekly for Total Coliforms, and E.coli bacteria testing. Testing is provided by the BC Centre for Disease Control through Interior Health. Only adverse sample results are reported to the Regional District. There has been no adverse treated water sample results during the monitoring period.

2.4 Raw Water Bacteriological

A raw water sample is taken bi-weekly for Total Coliforms, E.coli and Fecal Coliform bacteria testing. Testing is conducted by Passmore Laboratory Ltd. Sample test results for the monitoring period are summarized in the following table.

Sample Date	Total Coliform (Colony Count per 100 ml)	E.coli (Colony Count per 100 ml)	Fecal Coliforms (Colony Count per 100 ml)
2021-01-04	17	Less than 1	Less than 1
2021-01-18	4	Less than 1	Less than 1
2021-02-01	2	Less than 1	Less than 1
2021-02-17	2	Less than 1	Less than 1
2021-03-01	8	Less than 1	Less than 1
2021-03-16	3	Less than 1	Less than 1
2021-03-29	10	Less than 1	Less than 1
2021-04-14	10	Less than 1	Less than 1
2021-05-12	2	Less than 1	Less than 1
2021-05-31	8	Less than 1	Less than 1
2021-06-01	16	Less than 1	Less than 1
2021-06-08	41	Less than 1	Less than 1
2021-06-22	21	Less than 1	Less than 1
2021-07-21	58	Less than 1	1
2021-08-03	Less than 1	Less than 1	2
2021-08-17	70	30	31
2021-09-01	23	Less than 1	Less than 1
2021-09-14	37	Less than 1	Less than 1
2021-09-28	23	Less than 1	Less than 1
2021-10-12	15	Less than 1	Less than 1
2021-10-26	10	Less than 1	Less than 1
2021-09-11	14	Less than 1	Less than 1
2021-11-30	50	Less than 1	Less than 1
2021-07-12	5	Less than 1	Less than 1
2021-12-21	2	Less than 1	Less than 1
2022-01-04	23	Less than 1	Less than 1

The following chart provides the historical Quartz Creek Total Coliform, Fecal Coliform and E.coli sample test results.



2.5 Raw Water Full Comprehensive

Raw Water Full Comprehensive test results are summarized in the following table.

Sample Date	Comments
2019-07-26	Test results within Canadian Drinking Water Quality Guidelines.
2019-10-22	Total Coliform count of 11. All other test results within Canadian Drinking Water Quality Guidelines.
2019-12-09	Test results within Canadian Drinking Water Quality Guidelines.
2020-03-30	Test results within Canadian Drinking Water Quality Guidelines.
2020-07-28	Total Coliform count of 71. Test results within Canadian Drinking Water Quality Guidelines.
2020-10-19	Test results within Canadian Drinking Water Quality Guidelines.
2021-01-27	Test results within Canadian Drinking Water Quality Guidelines.
2021-04-06	Test results within Canadian Drinking Water Quality Guidelines.
2021-07-05	Test results within Canadian Drinking Water Quality Guidelines.
2021-10-27	Test results within Canadian Drinking Water Quality Guidelines.
2020-01-28	Test results within Canadian Drinking Water Quality Guidelines.

2.6 Treated Water THM & HAA

Some studies have identified a potential link between disinfection byproducts, primarily trihalomethanes (THMs) and haloacetic acids (HAAs) and certain forms of cancer. Disinfection byproducts can be formed when chlorine reacts with source water that has higher levels of organic material.

Guidelines for Canadian Drinking Water Quality: Guideline Technical Document – Trihalomethanes, April 2009 addendum, identifies the maximum acceptable concentration (MAC) for trihalomethanes (THMs) in drinking water as 0.100 mg/L (100 µg/L) based on a locational running annual average of a minimum of quarterly samples taken at the point in the distribution system with the highest potential THM levels. The maximum acceptable concentration (MAC) for bromodichloromethane (BDCM) in drinking water is 0.016 mg/L (16 µg/L) monitored at the point in the distribution system with the highest potential THM levels.

Guidelines for Canadian Drinking Water Quality: Guideline Technical Document – Haloacetic Acids, 2008 identifies the maximum acceptable concentration (MAC) for total haloacetic acids in drinking water at 0.08 mg/L (80 µg/L) based on a locational running annual average of a minimum of quarterly samples taken in the distribution system.

Sample test results for the monitoring period are summarized in the following table.

Sample Date	Total Trihalomethanes (mg/L)	Bromodichloromethane (mg/L)	Total Haloacetic Acids (mg/L)
2019-01-28	0.0109	< 0.0010	0.00774
2019-07-17	0.0207	< 0.0010	0.0145
2020-06-18	0.0227	< 0.0010	0.0205
2020-09-21	0.0118	< 0.0010	0.0106
2021-01-04	0.0188	< 0.0010	0.0130
2021-04-06	0.0179	< 0.0010	0.0140
2021-06-14	0.0206	< 0.0010	0.0110
2021-09-13	0.0198	< 0.0010	0.0150

Sample results are below Guidelines for Canadian Drinking Water Quality guideline maximum acceptable concentrations.

Appendix A

Quartz Creek Flow Monitoring Weir Formula



Ymir Water System Quartz Creek Flow Monitoring Weir Formula

Jason McDiarmid, revised 31 August 2020 for widened Overflow

There are two commonly used formulas for calculation of flows over contracted rectangular weirs provided by the US Burrow of Land Reclamation. The following simplified formula could be used if dimensions of the weir and flow meet certain criteria. The proposed weir opening for Quartz Creek is 40 inches wide x 22 inches high. One of the requirements of the simplified formula is that the width of the weir be at least 3 times greater than the flow height. This means that the formula could only be used for flows heights of less than 7.33 inches (186 mm), which would not work for the Quartz Creek flow weir.

$$Q = 3.33(L - 0.2H)H^{3/2}$$

Kindsvater-Carter Formula

The Kindsvater-Carter formula as follows is more complicated:




Figure 1: Weir Profile




Figure 2: Weir Elevation

$$Q = C_e L_e H_e^{3/2}$$

Where:

Q is the discharge in ft^3/s .

C_e is the effective coefficient of discharge.

$$L_e = L + k_b$$

$$H_e = H + k_h$$

L is the length of the weir crest in feet, 3.333 feet.

B is the average width of the approach channel in ft, 30 feet.

H is the head measured above the weir crest in feet, 0 to 1.833 feet to top of weir.

k_h is a correction factor having a value of 0.003 feet.

k_b depends on the ratio of crest length to average width of approach channel (L/B), $(3.333 / 30) = 0.111$

P is the depth from the weir invert to the bottom of the approach pool in feet, 7 feet when pool has no sediment.

k_b can be determined from L/B and Figure 3. $L/B = 3.333 / 30 = 0.111$; therefore, $k_b = 0.0083$.




Figure 3: k_b , Bureau of Land Reclamation Water Measurement Manual

C_e can be determined from Figure 4 based on L/B and H/P . $L/B = 3.333 / 30 = 0.111$, $P = 7$ feet and H varies from 0 to 1.833 feet; therefore, H/P varies from 0 to $(1.833/7)$ or 0 to 0.262.

With an L/B of 0.111, C_e can be interpreted as being about constant at 3.15 for an H/P of 0 to 0.262.




Figure 4: C_e , Bureau of Land Reclamation Water Measurement Manual

With the known information for the proposed Quartz Creek weir the flow formula and be provided as follows for dimensions in feet and flow rate of cubic feet per second:

$$Q = C_e L_e H_e^{3/2}$$

$$Q = C_e (L + k_b) (H + k_h)^{3/2}$$

$$Q = 3.15 (3.333 + 0.0083) (H + 0.003)^{3/2}$$


$$Q = 10.525 (H + 0.003)^{3/2}$$

The calculated flow rate in cubic feet per second can then be multiplied by 28.317 to convert it to L/s.

Overflow Weir – Up to 20 August 2020

The flow measurement weir has been sized for better accuracy on low flows. Because the flow measurement weir is smaller than the previous concrete intake weir openings, it is likely that the flow measurement weir will overtop during high flow events. End plates were added to the concrete intake weir to create a second wider flow weir above the main flow weir to capture higher flow events.

The Kindsvater-Carter Formula was not likely intended for complex weirs, so flow calculation might only be considered an estimation only for the overflow weir. In addition, supports for a catwalk above the concrete weir would slightly disrupt flow and the catwalk would only accommodate 6" of overflow before the flow is significantly disrupted.



The following assumes that two separate Kindsvater-Carter calculations can be done: one for flow through the main flow measurement weir; and one for over topping flows. The two flow calculations could then added together to get an estimation of total flow.

The Kindsvater-Carter formula for overflow flows would be as follows:

$$Q = C_e L_e H_e^{3/2}$$

Where:

Q is the discharge in ft^3/s .

C_e is the effective coefficient of discharge.

$$L_e = L + k_b$$

$$H_e = H + k_h$$

L is the length of the weir crest in feet, 21.688 feet.

B is the average width of the approach channel in ft, 30 feet.

H is the head measured above the weir crest in feet, 0 to 0.500 feet to top of weir.

k_h is a correction factor having a value of 0.003 feet.

k_b depends on the ratio of crest length to average width of approach channel (L/B), $(21.688 / 30) = 0.723$

P is the depth from the weir invert to the bottom of the approach pool in feet, 7 feet when pool has no sediment.

k_b can be determined from L/B and Figure 3. $L/B = 21.688 / 30 = 0.723$; therefore, $k_b = 0.014$.




Figure 3: k_b , Bureau of Land Reclamation Water Measurement Manual

C_e can be determined from Figure 4 based on L/B and H/P . $L/B = 21.688 / 30 = 0.723$, $P = 7$ feet and H varies from 0 to 0.500 feet; therefore, H/P varies from 0 to $(0.500/7)$ or 0 to 0.071.

With an L/B of 0.723, C_e can be interpreted as about 3.18 for an H/P of 0 to 0.071.




Figure 4: C_e , Bureau of Land Reclamation Water Measurement Manual

With the known information for the proposed Quartz Creek overflow weir the flow formula and be provided as follows for dimensions in feet and flow rate of cubic feet per second:

$$Q = C_e L_e H_e^{3/2}$$

$$Q = C_e (L + k_b) (H + k_h)^{3/2}$$

$$Q = 3.18 (21.688 + 0.014) (H + 0.003)^{3/2}$$

$$Q = 69.012 (H + 0.003)^{3/2}$$

The calculated flow rate in cubic feet per second can then be multiplied by 28.317 to convert it to L/s.

Stage Discharge Curve

Figures 5 and 6 provide the Kindsvater – Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, in Imperial units and SI Units

Table 1: Quartz Creek Kindsvater-Carter Formula Flows Before 20 August 2020

Kindsvater-Carter Formula			Kindsvater-Carter Formula		
		Flow Height		Flow Height	
Q (cfs)	H (inches)	H (feet)	Q (L/s)	H (mm)	
0	0	0	0	0	
0.27	1	0.08	8	25	
0.74	2	0.17	21	51	
1.34	3	0.25	38	76	
2.05	4	0.33	58	102	
2.86	5	0.42	81	127	
3.75	6	0.50	106	152	
4.73	7	0.58	134	178	
5.77	8	0.67	163	203	
6.88	9	0.75	195	229	
8.05	10	0.83	228	254	
9.28	11	0.92	263	279	
10.6	12	1.00	299	305	
11.9	13	1.08	337	330	
13.3	14	1.17	377	356	
14.8	15	1.25	418	381	
16.3	16	1.33	460	406	
17.8	17	1.42	504	432	
19.4	18	1.50	549	457	
21.0	19	1.58	595	483	
24.4	21	1.75	692	533	
26.2	22	1.83	742	559	
27.9	23	1.92	791	584	
31.0	24	2.00	878	610	
35.0	25	2.08	990	635	
39.7	26	2.17	1,123	660	
45.0	27	2.25	1,273	686	
50.8	28	2.33	1,439	711	




Figure 5: Kindsvater–Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, Imperial Units Before 20 August 2020




Figure 6: Kindsvater – Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, SI Units Before 20 August 2020

Overflow Weir – Starting 20 August 2020

On 20 August 2020 a failed level sensor was replaced and the overflow weir was widened from 260 ¼" (21.688 feet) to 288 ¾" (24.063 feet) to accommodate more flow.

The Kindsvater-Carter formula for overflow flows would be as follows:

$$Q = C_e L_e H_e^{3/2}$$

Where:

Q is the discharge in ft³/s.

C_e is the effective coefficient of discharge.

$$L_e = L + k_b$$

$$H_e = H + k_h$$

L is the length of the weir crest in feet, 24.063 feet.

B is the average width of the approach channel in ft, 30 feet.

H is the head measured above the weir crest in feet, 0 to 0.500 feet to top of weir.

k_h is a correction factor having a value of 0.003 feet.

k_b depends on the ratio of crest length to average width of approach channel (L/B), $(24.063 / 30) = 0.802$

P is the depth from the weir invert to the bottom of the approach pool in feet, 7 feet when pool has no sediment.

k_b can be determined from L/B and Figure 3. $L/B = 24.063 / 30 = 0.802$; therefore, $k_b = 0.014$.




Figure 3: k_b , Bureau of Land Reclamation Water Measurement Manual

C_e can be determined from Figure 4 based on L/B and H/P . $L/B = 24.063 / 30 = 0.802$, $P = 7$ feet and H varies from 0 to 0.500 feet; therefore, H/P varies from 0 to $(0.500/7)$ or 0 to 0.071.

With an L/B of 0.802, C_e can be interpreted as about 3.18 for an H/P of 0 to 0.071.




Figure 4: C_e , Bureau of Land Reclamation Water Measurement Manual

With the known information for the proposed Quartz Creek overflow weir the flow formula and be provided as follows for dimensions in feet and flow rate of cubic feet per second:

$$Q = C_e L_e H_e^{3/2}$$

$$Q = C_e (L + k_b) (H + k_h)^{3/2}$$

$$Q = 3.18 (24.063 + 0.014) (H + 0.003)^{3/2}$$

$$Q = 76.565 (H + 0.003)^{3/2}$$

The calculated flow rate in cubic feet per second can then be multiplied by 28.317 to convert it to L/s.

Stage Discharge Curve

Figures 7 and 8 provide the Kindsvater – Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, in Imperial units and SI Units

Table 2: Quartz Creek Kindsvater-Carter Formula Flows After 20 August 2020

Kindsvater-Carter Formula			Flow Height	
Q (cfs)	H (inches)	H (feet)	Q (L/s)	H (mm)
0	0	0	0	0
0.27	1	0.08	8	25
0.74	2	0.17	21	51
1.34	3	0.25	38	76
2.05	4	0.33	58	102
2.86	5	0.42	81	127
3.75	6	0.50	106	152
4.73	7	0.58	134	178
5.77	8	0.67	163	203
6.88	9	0.75	195	229
8.05	10	0.83	228	254
9.28	11	0.92	263	279
10.6	12	1.00	299	305
11.9	13	1.08	337	330
13.3	14	1.17	377	356
14.8	15	1.25	418	381
16.3	16	1.33	460	406
17.8	17	1.42	504	432
19.4	18	1.50	549	457
21.0	19	1.58	595	483
24.4	21	1.75	692	533
26.2	22	1.83	742	559
28.1	23	1.92	797	584
31.5	24	2.00	893	610
35.9	25	2.08	1,018	635
41.1	26	2.17	1,165	660
47.0	27	2.25	1,331	686
53.5	28	2.33	1,515	711




Figure 7: Kindsvater–Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, Imperial Units After 20 August 2020




Figure 8: Kindsvater – Carter Formula Stage Discharge Curve for Quartz Creek, Ymir BC, SI Units After 20 August 2020



Quartz Creek Ymir Water Intake – 31 March 2020



Quartz Creek Flow Weir Discharge – 31 March 2020